
General Purpose ELS –1100 Series Satisfies Most Applications

These polysulfone units are both compact and economical. They feature a variety of mountings, power requirements and electrical terminations to make it easy to find a perfect match for your application.

Specifications

Materials Housing and Prism	Polysulfone or Nylon				
Operating Pressure	0 to 150 PSI, Maximum				
Operating Temperature*	0°F to 176°F (-17.8°C +80°C)				
Current Consumption	18 mA, Approximately				
Output†	TTL/CMOS Compatible. Open Collector Output May Sink 40 mA				
	UP TO 30 VDC.				
Repeatability	±1 mm				
EMI Susceptability	Isceptability Meets (MIL-STD-461B Part 2 Modified) Specification of 10 V for Frequency Range 30 to 1000 MHz (Except 609 MHz = 9 V and 679 MHz = 7.5 V/M).				



[†] See Page C-1 for Wiring Diagrams



Dimensions

	1/4" NPT Mounting 1/4" NPT Mounting with 3/8" Conduit		1/2" Straight Thread Mounting with O-ring	M12x1-8g Straight Thread with O-Ring	"Fish" Pull Ring	
	LEAD WIRES EPOXY ENCAPSULATED 5/8"HEX (15.9 mm) 1/4" NPT	3/8 *NPT MOUNTING 5/8 * HEX (15.9 mm) (54.7 mm)	2.5/32 * (15.9 mm) VITON * O-RING * UNF 2A	2-5/32" (15.9 mm) VITON® (0-RING) M12 x 1-8g	CABLE 5/8"HEX. (15.9 mm) REMOVABLE PVC FISH PULL RING	
Electrical Termination		25' Cable, 22 AWG, PVC Jacketed				

How To Order

Specify Part Number based on Mounting Type, Input Power and Output Condition required.

Input Power	Probe Condition at Current Sink	Mounting Type						
		1/4" NPT	1/4" NPT & 3/8" Conduit		1/2" Straight Thread	M12x1-8g Straight Thread	"Fish" Pull Ring	
		Polysulfone	Polysulfone	Nylon	Polysulfone	Polysulfone	Polysulfone	
5 VDC	Wet	138167 🗲	144225	175631	144235	166541	-	
10-28 VDC	Wet	142700 🗲	143585 🗲	157750	143580	169555	143577	
	Dry	143570	143590	175632	143575	169556	148973	

Intrinsically-Safe Versions

GEMS ELS-1100 Switches may be rendered intrinsically-safe for Class I, Division 1, Group C & D when used with appropriate GEMS Zener Barriers. Call Gems Sensors for special ELS-1100-IS (intrinsically-safe) part numbers and Installation Bulletins 148745 and 148744, File No. E44570.