Distance-settable Photoelectric Sensor E3Z-LS

Selectable Foreground/Background Suppression Photoelectric Sensor

- Stable sensing regardless of target's color or size.
- Adjustable sensing distance.
- Unique Algorithm minimizes external interference from fluorescent lighting.
- Visible light ensures easy alignment.
- Available in pre-wired or connector-ready configuration.



Ordering Information

■ Sensors

Sensing	Appearance	Connection	Sensing distance (white paper)	Model		
method (selectable)		method		NPN output	PNP output	
BGS/FGS diffuse		Pre-wired (2-m cable)	20 mm 40 mm 200 mm Incident light level threshold (fixed) BGS (at max. setting) BGS (at max. setting)	E3Z-LS61	E3Z-LS81	
		M8 Connector	FGS (at min. setting) FGS (at max. setting)	E3Z-LS66	E3Z-LS86	

■ Accessories (Order Separately)

Sensor I/O Connectors

Cable specification		Appearance	Cab	Cable type		
Standard M8 cable	Straight		2 m	4-wire	XS3F-M421-402-A XS3F-M421-405-A	
	L-shaped		2 m		XS3F-M422-402-A XS3F-M422-405-A	

OMRON

Mounting Brackets (Same for Entire E3Z Series)

Appearance	Qty	Remarks	Model	Appearance	Qty	Remarks	Model
	1	Mounting Bracket			1 set	Sensor Adjusters For easy mounting and adjustment with aluminum frames and rails, such as those on conveyors For horizontal adjustment	E39-L150
io a	1		E39-L104				
6	1	Horizontal Mounting Bracket	E39-L43		1 set		E39-L151
	1	Horizontal Protective Cover/ Mounting Bracket	E39-L142	,			
gal gal	1	Rear-connecting Mounting Bracket	E39-L44				
	1	Protective Cover/ Mounting Bracket	E39-L98		1 set	Compact Protective Cover/ Mounting Bracket (for E3Z only)	E39-L144

Specifications

■ Ratings/Characteristics

Sensing method		Distance-settable					
Item	NPN output	E3Z-LS61	E3Z-LS66				
	PNP output	E3Z-LS81	E3Z-LS86				
Sensing distance	BGS	White or black paper (100 x 100 mm): 20 mm to 20	0 mm				
(see Operation)	FGS	White paper (100 x 100 mm): 40 mm to 200 mm Black paper (100 x 100 mm): 40 mm to 160 mm					
Adjustable sensing ra	nge (see note)	White paper (100 x 100 mm): 40 to 200 mm Black paper (100 x 100 mm): 40 to 160 mm					
Hysteresis		(Refer to the "Hysteresis vs. Sensing Distance" gra	ph in the <i>Engineering</i> section of this data sheet.)				
Reflectivity characteri (black/white error)	stic	10% of set distance max.					
Light source (wavelen	gth)	Red LED (680 nm)					
Power supply voltage		12 to 24 VDC ±10%, ripple (p-p) 10% max.					
Current consumption		30 mA max.					
Control output		Load power supply voltage 26.4 VDC max., load current 100 mA max. (residual voltage 1 V max.) Open collector output (NPN or PNP depending on model) Light-ON/Dark-ON switch selectable					
BGS/FGS selection (wire selectable)		BGS: Open or connected to GND FGS: Connected to Vcc (See Operation)					
Protective circuits		Reverse polarity protection, output short-circuit protection, mutual interference prevention					
Response time		Operation or reset: 1 ms max.					
Distance setting		5-turn adjuster					
Ambient illumination		Incandescent lamp: 3,000 lx max.; Sunlight: 10,000 lx max.					
Ambient temperature		Operating: -25 to 55°C, Storage: -40 to 70°C (with no icing or condensation)					
Ambient humidity		Operating: 35% to 85%, Storage: 35% to 95% (with no condensation)					
Insulation resistance		$20~\text{M}\Omega$ min. at $500~\text{VDC}$					
Dielectric strength		1,000 VAC at 50/60 Hz for 1 minute					
Vibration resistance (10 to 55 Hz, 1.5-mm double amplitude for 2 hours each in X, Y, and Z directions					
Shock resistance (des	truction)	500 m/s² for 3 times each in X, Y, and Z directions					
Degree of protection		IEC 60529 IP67					
Connection method		Pre-wired (standard length: 2 m/0.5 m) M8 connector					
Indicators		Operation indicator (orange), stability indicator (green)					
Weight (packed state)		Pre-wired Sensors, 2 m: Approx. 65 g Approx. 20 g					
Material	Case	PBT (polybutylene terephthalate)					
	Lens	Denaturated polyallylate					
Accessories		Instruction sheet (Mounting Brackets must be purch	nased separately.)				

Note: The sensing range of an object that has reflectivity that is similar to a white paper can be adjusted from 40 to 200 mm. The sensing range of an object that has reflectivity that is similar to a black paper can be adjusted from 40 to 160 mm.

Principle of Operation


■ Background Suppression

Background Suppression: Objects beyond the set distance will not be detected.

To ensure reliable background suppression, a minimum separation distance between the set distance and the background is recommended. Please refer to the "Hysteresis vs. Sensing Distance" graph in the *Engineering* section of this data sheet to determine the minimum separation distance.

Example: A target that has a reflectivity that is similar to a black paper is set to a maximum set distance of 160 mm. Based on the "Hysteresis vs. Sensing Distance" graph, the hysteresis is 5%. The recommended minimum separation distance in this case is 8.0 mm (5% of 160 mm) between the background and the set distance. This means that the background must be at least 8.0 mm behind the set distance.

Background Suppression Optical Configuration



■ Foreground Suppression

Foreground suppression: Objects in front of the set distance will not be detected.


Objects with glossy or irregular surface often reflect the light emitted from the sensor in different directions. This phenomenon often leads to false detection. For such objects, a foreground suppression sensor (FGS) or a polarized retro-reflective sensor is the sensor of choice. For applications that do not have space for a reflector, the FGS is ideal

FGS sensors accomplish reliable detection by not detecting the object directly. An FGS sensor uses a background, as a retro-reflective sensor would use a reflector, to reliably detect any object that passes between itself and the background. FGS uses the position on which the light reflected from the background strikes its receiver as a point of reference (see the diagram at right.) A change in switching state occurs when the light strikes the receiver at a different position. Any object that passes between the sensor and the background will reflect the light onto the receiver in a position that will be different from the point of reference (reflection from the background).


To ensure reliable foreground suppression, a minimum separation distance between the set distance and the background as well as a minimum separation distance from the target to the set distance is recommended. Please refer to the "Hysteresis vs. Sensing Distance" graph in the *Engineering* section of this data sheet to determine the minimum separation distance.

Example: A target that has a reflectivity that is similar to a black paper is set to a maximum set distance of 160 mm. Based on the "Hysteresis vs. Sensing Distance" graph, the hysteresis is 5%. The recommended minimum separation distance in this case is 8.0 mm (5% of 160 mm) between the background and the set distance, and 8.0 mm between the set distance and the background. This means that the background must be at least 8.0 mm behind the set distance, and the set distance must be at least 8.0 mm behind the target.

Foreground Suppression Optical Configuration



Operation



Note: The VERY FAR region is supported only for FGS. The incident light level threshold is fixed and cannot be set.


■ NPN Output

Model	Output transis- tor status	Timing chart	Mode selec- tion switch	BGS/FGS selection method	Output circuit
E3Z-LS61 E3Z-LS66	Light ON	Operation on indicator (orange) OFF Output ON transistor OFF Load (e.g., ON relay) OFF (Between brown and black)	L side (L/ON)	BGS: Either leave the pink wire (2) open or connect it to the blue wire (3).	
	Dark ON	Operation indicator ON ON ON Indicator OFF Output ON transistor OFF Load (e.g., ON relay) OFF (Between brown and black)	D side (D/ON)	FGS: Connect the pink wire (2) to the brown wire (1).	Operation indicator (green) Main (Control output) Brown 12 to 24 VDC Pink FGS Load (relay) 100 mA Black max. 2D BGS BUS BUS BUS O V
	in (c O tr	Operation indicator ON (orange) OFF Output ON transistor OFF Load (e.g., ON relay) OFF (Between brown and black)	L side (L/ON)		Connector Pin Arrangement (2 4) (3 9)
	Dark ON	Operation indicator ON (orange) OFF Output ON transistor OFF (Operation) OPF (D side (D/ON)		

■ PNP Output

Model	Output transis- tor status	Timing chart	Mode selec- tion switch	BGS/FGS selection method	Output circuit
E3Z-LS81 E3Z-LS86	Light ON	Operation ON indicator (orange) OFF Output ON transistorOFF Load (e.g.,ON relay) OFF (Between blue and black)	L side (L/ON)	BGS: Either leave the pink wire (2) open or connect it to the blue wire (3).	
	Dark ON	Operation ON Indicator (orange) OFF Output ON transistor OFF Load (e.g., ON relay) OFF (Between blue and black)	D side (D/ON)	FGS: Connect the pink wire (2) to the brown wire (1).	Operation indicator (green) Main circuit Operation indicator (orange) Brown 12 to 24 VDC FGS Black I 100 mA max. Load (relay) Blue BGS O V
	Light ON	Operation ON INFORMATION ON INFORMAT	L side (L/ON)		Connector Pin Arrangement
	Dark ON	Operation indicator (orange) OFF Output ON transistor OFF Load (e.g., ON relay) OFF (Between blue and black)	D side (D/ON)		


■ Connectors (Sensor I/O Connectors)




Class	Wire jacket color	Connector pin No.	Application
For DC	Brown	1	Power supply (+V)
	White	2	BGS/FGS selection
	Blue	3	Power supply (0 V)
	Black	4	Output

Engineering Data


Operating Range BGS



FGS




Spot Diameter vs. Sensing **Distance**




Inclination Characteristics


Vertical



Horizontal




Short-distance Characteristic




FGS Mode Set Distance vs. **Sensing Range**


White Paper



Black Paper




Hysteresis vs. **Sensing Distance**




Sensing Distance vs. Material


At Set Distance of 40 mm



At Set Distance of 200 mm



Nomenclature




Dimensions

Unit: mm (inch)

Pre-wired Sensors

E3Z-LS61 E3Z-LS81 20 (0.79) 12.7 Operation indicator (orange) 10.8 (0.43) 10.4 Set distance adjuster Operation selector Stability indicator (green) Receiver 2.1 Optical axis (1.22) 25.4 13.5 Two, M3 4-dia., 4-core vinyl-insulated round cable (conductor cross-sectional area: 0.2 mm²; insulation diameter: 1.1 mm) Standard length: 2 m/0.5 m

Sensors with M8 Connectors



Precautions



Do not connect an AC power supply to the Sensor. If AC power (100 VAC or more) is supplied to the Sensor, it may explode or burn.

Be sure to abide by the following precautions for the safe operation of the Sensor.

Wiring

Power Supply Voltage and Output Load Power Supply Voltage

Make sure that the power supply to the Sensor is within the rated voltage range. If a voltage exceeding the rated voltage range is supplied to the Sensor, it may explode or burn.

Load Short-circuiting

Do not short-circuit the load, otherwise the Sensor may be damaged.

Connection without Load

Do not connect the power supply to the Sensor with no load connected, otherwise the internal elements may explode or burn.

Operating Environment

Do not use the Sensor in locations with explosive or flammable gas.

■ Correct Use

Design

Power Reset Time

The Sensor is ready to operate 100 ms after the Sensor is turned ON. If the load and Sensor are connected to independent power supplies respectively, be sure to turn ON the Sensor before supplying power to the load.

Wiring

Avoiding Malfunctions

If using the Photoelectric Sensor with an inverter or servomotor, always ground the FG (frame ground) and G (ground) terminals, otherwise the Sensor may malfunction.

Mounting

Mounting the Sensor


- If Sensors are mounted face-to-face, make sure that the optical axes are not in opposition to each other. Otherwise, mutual interference may result.
- Always install the Sensor carefully so that the aperture angle range
 of the Sensor will not cause it to be directly exposed to intensive
 light, such as sunlight, fluorescent light, or incandescent light.
- Do not strike the Photoelectric Sensor with a hammer or any other tool during the installation of the Sensor, or the Sensor will lose its water-resistive properties.
- Use M3 screws to mount the Sensor.
- When mounting the case, make sure that the tightening torque applied to each screw does not exceed 0.54 N·m.

M8 Connector


- Always turn OFF the power supply to the Sensor before connecting or disconnecting the metal connector.
- Hold the connector cover to connect or disconnect it.
- Secure the connector cover by hand. Do not use pliers, otherwise the connector may be damaged.
- If the connector is not connected securely, it may be disconnected by vibration or the proper degree of protection of the Sensor may not be maintained.

Mounting Directions


 Make sure that the sensing side of the Sensor is parallel with the surface of the sensing objects. Normally, do not incline the Sensor towards the sensing object.




If the sensing object has a glossy surface, however, incline the Sensor by 5° to 10° as shown in the illustration, provided that the Sensor is not influenced by background objects.




 If there is a mirror-like object below the Sensor, the Sensor may not operate stably. Therefore, incline the Sensor or separate the Sensor from the mirror-like object as shown below.



Do not install the Sensor in the wrong direction. Refer to the following illustration.




Install the Sensor as shown in the following illustration if each sensing object greatly differs in color or material.



Adjustments

Indicator Operation



Note: 1. If the stability indicator is lit, the detection/no detection status is stable within the rated ambient operating temperature (-25 to 55°C).

The VERY FAR region is supported only for FGS. The incident light threshold is fixed and cannot be set. The distance to the incident light threshold depends on the color and gloss of the sensing object's surface.

Inspection and Maintenance

Cleaning

Never use paint thinners or other organic solvents to clean the surface of the product.

E3Z Series

■ Complete E3Z Series

Sensing method Item			Retroflective	Retroflective for PET bottles		Through-beam		Grooved type		
Appearance									*	
Model	E3Z-LS	E3Z-D	E3Z-L	E3Z-R	E3Z-B		E3Z-T		E3Z-G	
Sensing distance	20 mm to set distance (BGS mode) Set distance to 200 mm min. (FGS mode)	5 to 100 mm (wide vision) 1 m	90 ±30 mm	4 m (100 mm) (See note 1.)	500 mm (80 mm) (See note 1.)	2 m (500 mm) (See note 1.)	15 m	10 m	25 mm	
Light source (wave- length)	Red LED (680 nm)	Infrared LED (860 nm)	Red LED (670 nm)	Red I	_ED (680 nm)		Infrared LED (860 nm)	Red LED (700 nm)	Infrared LED (940 nm)	
Power supply voltage	12 to 24 VDC ±10%, ripple (p-p) 10% max.									
Current consump- tion	30 mA max. Emitter: 15 mA Receiver: 20 mA								25 mA max.	
Control outputs	Load power supply of Open collector output Light-ON/Dark-ON s	ut (NPN or PNP depe	k., load current 100 mA nding on model)	a max. (residual voltage	V max.)					
Protective circuits	Reverse polarity pro	tection, output short-	circuit protection, mutua	al interference prevention	n (Mutual interfe	rence preventior	is not provided	on E3Z-T.)		
Response time	Operation or reset: 1	I ms max.								
Sensitivity adjustment	5-turn endless adjuster Single-turn adjuster									
Ambient temperature	Operating: -25 to 55	5°C, Storage: -40 to 7	0°C (with no icing or co	ondensation)						
Ambient humidity	Operating: 35% to 8	Operating: 35% to 85%, Storage: 35% to 95% (with no condensation)								
Protective structure	IEC 60529 IP67								IEC 60529 IP64	
Connection method	Pre-wired (standard length: 2 m/0.5 m) or M8 connector	Pre-wired (standard length: 2 m/0.5 m), M8 connector, or M1 connector relay (0.3 m)	Pre-wired (standard length: 2 m/0.5 m) or M8 connector	Pre-wired (standard length: 2 m/0.5 m), M8 connector, or M12 connector relay (0.3 m)	Pre-wired (star 2 m/0.5 m) or I		Pre-wired (star 2 m/0.5 m), M8 M12 connector infrared type or	connector, or relay (0.3 m,	Pre-wired (standard length: 2 m/0.5 m) or M8 connector relay (0.3 m)	

Note: 1. The sensing distance is for when an E39-R1S Reflector is used. The minimum distance between the Reflector and Sensor is given in parentheses.

2. For details, refer to the Sensing Products catalog (CEDSAX).



ALL DIMENSIONS SHOWN ARE IN MILLIMETERS. To convert millimeters into inches, divide by 25.4

OMRON

OMPON ELECTRONICS LLC

One East Commerce Drive Schaumburg, IL 60173

1-800-55-OMRON

Cat. No. E327-E3-1

08/02/7.5M

OMRON ON-LINE

Global - http://www.omron.com USA - http://www.omron.com/oei Canada - http://www.omron.com/oci OMRON CANADA, INC. 885 Milner Avenue

Toronto, Ontario M1B 5V8

416-286-6465

Specifications subject to change without notice

Printed in USA